

[1]

No.19/Advice/CFO/MZ/2017

Office of the Chief Fire Officer  
Karnataka Fire & Emergency Services  
Mysuru Zone, Saraswathipuram  
Mysuru - 570 009  
DATE:- 28-06-2017.

To,  
The Principal  
Citizen Public School  
#299/1/2, K.H.B Colony, Ooty road,  
Nanjangudu, Mysuru dist.- 571 301.

Sir,

Sub: Issue of 'Fire Safety Advice Certificate' to Citizens Public School  
#299/1/2, K.H.B Colony, Ooty road, Nanjangudu, Mysuru district  
-571 301.

Ref: 1. Your letter dated:- 19-06-2017.  
2. DFO Report No.06/School/DFO/SFS/2017, dated: 27-06-2017

\*\*\*\*\*

With reference to the subject cited above, the premises of Citizens Public School, #299/1/2, K.H.B Colony, Ooty road, Nanjangudu, Mysuru district-571 301 was inspected by the District Fire Officer, Saraswathipuram, Mysuru on 23-06-2017 with respect to fire prevention, fire fighting and evacuation measures to be complied in the above premises and has submitted the details as under:

**A. Details of the building**

1. Address of the premises : Citizens Public School  
#299/1/2, K.H.B Colony, Ooty road,  
Nanjangudu, Mysuru dist. - 571 301.
2. Number of building : One Building.
3. Number of floors : Ground Floor and 3 Upper floors.
4. Floor wise details of occupancy
  - Ground Floor : 8 Class rooms, 1 Office room, 1 Computer lab.
  - 1<sup>st</sup> Floor : 9 Class rooms, 1 Science lab.
  - 2<sup>nd</sup> Floor : 10 Class rooms.
  - 3<sup>rd</sup> Floor : 10 Class rooms.
5. Height of the building : 14.40 mtrs.
- Site area : 02 Acres.

*Mahesh B. B.*

**PRESIDENT  
CITIZENS' EDUCATION SOCIETY  
NANJANGUD-571301**

*[Signature]*  
**CITIZENS PUBLIC SCHOOL  
K.H.B. COLONY, OOTY ROAD,  
NANJANGUD-571301**



7. **Built up area of each floor**

Ground floor	: 489.36 sq. mtrs.
First floor	: 489.36 sq. mtrs.
Second floor	: 489.36 sq.mtrs.
Third floor	: 489.36 sq.mtrs.
<b>Total</b>	<b>: 1957.44 Sq.mtrs.</b>

8. Type of construction : RCC Building.

9. **Surroundings**

East	: 9.00 mtrs. wide road.
West	: 12.00 mtrs. Wide Chennappa layout road.
North	: Open land.
South	: K.H.B houses.

10. Name and address of the building owner : Smt. Mashooda Begum  
w/o Late. Javeed Ahmed  
#299/1/2, K.H.B Colony, Ooty road  
Nanjangudu, Mysuru dist. -571 301

11. Name and address of applicant : The Principal  
Citizens Public School  
#299/1/2, K.H.B Colony, Ooty road  
Nanjangudu  
Mysuru district-571 301.

12. Number of students : Students : 1796  
Employees : 48

**B. On inspection of the school premises, the following fire protection, fire fighting and evacuation measures are recommended and they are absolutely essential.**

Details (1)	Existing (2)	Recommendations (3)
1. Approach to the premises	9.00 mtrs. & 12.00 mtrs. wide roads accessibility from Eastern & Western sides.	The requirement is complied with.
2. Width of open space	East : 02.00 mtrs. West : 02.00 mtrs. North : 62.00 mtrs. South : 02.00 mtrs.	The requirement is not complied with. Minimum 5.00 mtrs. Setbacks all around the building shall be kept free from any construction or obstruction for the easy movements of Emergency vehicles.



*Mashooda Begum*  
**PRESIDENT**  
**CITIZENS' EDUCATION SOCIETY**  
**NANJANGUD-571301**

*[Signature]*  
**CITIZENS' PUBLIC SCHOOL**  
**K.H.B. COLONY, OOTY ROAD,**  
**NANJANGUD-571 301**

3. Number of Stair cases      Provided 1 no. staircase of 1.50 mtrs. width.      **The requirement is not complied with.**  
Recommended to provide one more staircase for emergency purpose use.
4. Portable Fire extinguishers      Provided as below      Recommended to provide fire extinguishers as below.

Sl No	Location	Existing Fire Extinguisher type & Capacity	Recommendations
1.	Ground floor	Provided 02 nos. water Co2 type fire extinguishers of 9 ltrs. capacity, 02 nos. Co2 type fire extinguisher of 2.5 kgs. capacity.	In addition to this recommended to provide 02 nos. Co2 fire extinguishers each of 9 ltrs. Capacity, 02 nos. Co2 type fire extinguishers each of 2 kgs. Capacity, 02 nos. ABC fire extinguishers each of 5 kgs. Capacity & 4 nos. fire buckets with stand.
2.	First floor	Provided 02 nos. DCP ype fire extinguisher of 4 kgs. capacity.	In addition to this recommended to provide 02 nos. Co2 fire extinguishers each of 9 ltrs. Capacity, 02 nos. Co2 type fire extinguishers each of 2 kgs. Capacity, 02 nos. ABC fire extinguishers each of 5 kgs. Capacity & 4 nos. fire buckets with stand.
3.	Second floor	--	Recommended to provide 02 nos. Co2 fire extinguishers each of 9 ltrs. Capacity, 02 nos. Co2 type fire extinguishers each of 2 kgs. Capacity, 02 nos. ABC fire extinguishers each of 5 kgs. Capacity & 4 nos. fire buckets with stand.
4.	Third floor	--	Recommended to provide 02 nos. Co2 fire extinguishers each of 9 ltrs. Capacity, 02 nos. Co2 type fire extinguishers each of 2 kgs. Capacity, 02 nos. ABC fire extinguishers each of 5 kgs. Capacity & 4 nos. fire buckets with stand.

5. Fire Prevention Measures      Not Indicated

1) Explosive and inflammable materials should not be stored in the premises.

2) Accumulations of combustible waste in and around the premises shall be avoided.



*Mahesh B. B.*  
**PRESIDENT**  
**CITIZENS' EDUCATION SOCIETY**  
**NANJANGUD-571301**

*[Signature]*  
**PRINCIPAL**  
**CITIZENS' PUBLIC SCHOOL**  
**K.H.B. COLONY, DUTY ROAD,**  
**NANJANGUD-571301**

3) The doors shall not be kept locked during working hours and shall be free obstructions.

6. Escape route Not Marked.

Directions in which the students have to move in the event of any emergency shall be indicated in the corridor during evacuation. It should be written in luminous paint in both blocks.

7. First Aid Box Provided 02 nos. first aid boxes in whole building.

In addition to this recommended to provide 02 nos. First aid box in each floor.

8. Fire order Not Displayed.

A notice board written in bold letters indicating the action to be taken by the employees in case of any emergency shall be displayed near staircase and the notice board should contain telephone number of Nanjangud Fire Station 08221-224144 & 101 and ambulance service at near staircases.

9. Fire alarm system Not provided.

Recommended to provide fire alarm system at each floor.

10. Hose reel hose system Not provided.

Recommended to provide Hose reel hose of 12 mm size & of adequate length to reach the farthest point of each floor near each staircase with a shut off branch.

This hose reel hose shall be connected to an over head tank of 10,000 ltrs. Capacity with an booster pump, capable of delivering 450 ltrs. of water per minute.

*Mahesh B. B.*  
**PRESIDENT**  
**CITIZENS' EDUCATION SOCIETY**  
**NANJANGUD-571301**



*[Signature]*  
**PRINCIPAL**  
**CITIZENS' PUBLIC SCHOOL**  
**K.H.B. COLONY, OOTY ROAD,**  
**NANJANGUD-571301**

11 No smoking board Not displayed

"No Smoking Area" & Smoking here is an offence board should be written in English & Kannada both languages shall be displayed at School premises & entry & exits of the building.

12 Training to Employees Not Trained

40% of the employees should be got trained in fire prevention, fire fighting and evacuation measures at R.A Mundkur Fire & Emergency Services Academy, Bannerghatta Road, Bangalore at an early date.

**Fire Precautionary Measures:-**

- The exit ways shall be kept clear always without any obstructions.
- The exit ways shall be marked with using illuminating paint.
- No fire in any form shall be used in the premises.
- Inflammable and explosive materials shall not stored in the area.
- 'No Smoking' boards shall be displayed at appropriate places in the premises.
- 2 emergency lights covering the floors shall be installed.
- The doors shall not be kept locked/latched during working hours.

Under the above circumstance the Karnataka Fire & Emergency Service Department is issuing 'Fire Safety Advice Certificate' to Citizens Public School, Sy.no. 299/1/2, K.H.B Colony, Ooty road, Nanjangud, Mysuru dist.-571 301 subject to condition and compliance of the above recommendations in column 2, 3, 4, 5, 6, 7, 8, 9, 10, 11 & 12 of serial - B within 3 months and compliance to the undersigned, if failed, this 'Fire Advice Certificate' will be cancelled.

This 'Fire Advice Certificate' is issued for a period of only one year from the date of issue and is renewable.

*Maheshwari Biju*  
PRESIDENT  
CITIZENS' EDUCATION SOCIETY  
NANJANGUD-571301

*Principi ..*  
PRINCIPAL  
CITIZENS' PUBLIC SCHOOL  
K.H.B. COLONY, OOTY ROAD,  
NANJANGUD-571301

Yours faithfully

*S. H. ...*  
Chief Fire Officer  
Karnataka Fire & Emergency Services  
Mysuru Zone, Saraswathipuram  
Mysuru - 570 009

1. Copy to District Fire Officer, Saraswathipuram, Mysuru-570 009.

Copy with compliments: Submitted to the Director General of Police and Director General, Karnataka Fire and Emergency Services, Bengaluru.

